

Access Statement

St David's Lleithyr Meadow

Contact Information

For those wishing to contact Caravan and Motorhome Club by phone, typetalk calls can be made to sites, and for members only to the Contact Centre on 01342 327490. The Caravan and Motorhome Club's website has been designed with accessibility in mind, and includes keyboard navigation and Browsealoud texthelp. The Website complies with the W3C level A guidelines.

Arrival and Car Parking Facilities

Space for new arrivals is provided next to reception at the site entrance. There is a level route to reception. There are no visitor parking bays adjacent to reception. There are 8 visitor car parking spaces located adjacent to the main toilet block. The site has no late arrivals area. The main site areas are not access controlled by a barrier.

Reception

The reception has a ramped approach set to a gradient of 1:16 with a single handrail. The entrance door achieves a 710mm opening width with a raised threshold of 30mm. The call bell is mounted at a height of 1500mm above floor level. Internally the reception area achieves adequate wheelchair manoeuvring and turning space in front of the reception counter which incorporates a low level position suitable for most users. The reception is not fitted with a hearing induction loop system to assist hearing aid users.

Pitches

The site has a total of 115 pitches all of which are grassed. The site has no pitches with a hard-standing and no fully serviced pitches with drainage and water supplies. 4 pitches are designated for disabled members, located on a level section of the site adjacent to the main toilet block.

Circulation around the Site

The site is reasonably level. Access roads around the site are shared by vehicles and pedestrians. There is a single principal access road around the site linking the reception, toilet block and service points. Pitches are provided either side of the main access road. Pitches located remote from the main access road are accessed over the grassed areas of the site.

Toilet Blocks

The site has one toilet block which is located to the north of the site. Approximately 8 car parking spaces are provided adjacent to the toilet block, of which 3 are located on a tarmac surfaced area at the front of the toilet block. There are no accessible car parking bays serving the toilet block. The toilet block is accessed via a dropped kerb with an upstand of 20mm. Pathways providing access to the toilet block are set to a gradient of approximately 1:15. The main entrance door to the toilet block achieves an opening width of 900mm with a raised chamfered threshold of 20mm. Circulation space to perimeter pathways does narrow to as little as 800mm at some points.

The **accessible WC and shower** door achieves an opening width of 860mm over a level threshold. The door is operated by a RADAR key available from reception. The cubicle size is 2150 x 2800mm. The level access shower and WC is designed for right hand transfer. Grab rails to the shower position may slightly obstruct lateral transfer from wheelchair to WC pan. The wash hand basin is positioned 600mm from the WC pan which may be out of reach to some users. The WC, basin and shower have ergonomic lever style controls and contrasting grab rails. There is no vertical grab rail to the side of the WC position. The wash



hand basin has a single vertical grab rail only. The shower position has no horizontal grab rails. The cubicle is fitted with an alarm system.

Male and female toilet doors achieve a 760mm opening width over a level threshold. Ambulant disabled WC and shower cubicles are provided with well contrasting grab rails. The shower cubicles are level access with a recessed drainage gully. WC's, wash hand basins and showers have ergonomic lever style controls.

Other Facilities

The **baby and toddler room** door achieves a clear opening width of 750mm over a level threshold. The door has a key pad lock set at a height of 1550mm. Internally facilities include a lowered toddler's WC, basin, small bath with shower over and a wall mounted baby changing unit set at a height of 840mm. The room does achieve adequate wheelchair manoeuvring and turning space. The wash hand basin is fitted with ergonomic lever style taps. The mixer tap to the bath is fitted with thumb turn taps.

The **laundry** door achieves an 860mm clear opening width over a level threshold. Internally the room achieves adequate wheelchair manoeuvring space. Washers and dryers are front loading and coin operated. Whilst counter mounted sinks are fitted with ergonomic lever style taps, the knee space to the underside of the counter is less than 700mm.

The **dishwashing area** door achieves an unrestricted opening width of 750mm over a level threshold. Internally the room achieves adequate wheelchair manoeuvring and turning space. Whilst counter mounted sinks are fitted with ergonomic lever style taps, the knee space to the underside of the counter is less than 700mm.

Service points are provided at regular intervals around the site providing drinking water, waste water, chemical waste disposal points, general waste and recycling facilities. Whilst the service point at the main toilet block is accessed from a dropped kerb, to remaining service points around the site facilities are mounted on a raised concrete plinth resulting in a step up on the approach.

A **children's play area** is located centrally on a grassed area of the site. Children's play equipment is mounted on grassed areas or a safety flooring system covered with bark chippings.

The site does not have an **information room**.